

Roads

Master Specification

RD-EL-C1 Installation of Lighting for Roads and Public Spaces

Document Information

K Net Number:	13469582
Document Version:	1
Document Date:	2/7/2019
Responsible Officer:	

DEPARTMENT OF
PLANNING, TRANSPORT
AND INFRASTRUCTURE



Government of South Australia
Department of Planning,
Transport and Infrastructure

Document Amendment Record

Version	Change Description	Date	Endorsement record (KNet ref.)
1	Initial issue (formerly R52). General document review and update; updated Referencing.	2/7/19	

Document Management

This document is the Property of the Department of Planning Transport and Infrastructure (DPTI) and contains information that is confidential to DPTI. It must not be copied or reproduced in any way without the written consent of DPTI. This is a controlled document and it will be updated and reissued as approved changes are made.

Contents

Contents	3
RD-EL-C1 Installation of Lighting for Roads and Public Spaces	4
1 General	4
2 Materials	4
3 Pole Footings	4
4 Trenching, Boring and Backfill	5
5 Assembly and Erection of Poles	5
6 Electrical Work	6
7 Supply Points	7
8 Service Points	7
9 Wiring	7
10 Luminaires	8
11 Lamps	8
12 Other Lighting	8
13 Acceptance	8
14 Removal of Existing Poles and Footings	8
15 Hold Points	9
16 Verification Requirements and Records	9
17 Appendix 1: Street Lighting Pole Assembly Instructions	10

RD-EL-C1 Installation of Lighting for Roads and Public Spaces

1 General

- 1.1 This Part specifies the requirements for the installation of lighting for roads and public spaces.
- 1.2 Documents referenced in this Part are listed below:
 - a) AS/NZS 2053 Conduits and Fittings for Electrical Installations.
 - b) AS/NZS 3000 Electrical Installations (known as the Australian/New Zealand Wiring Rules).
- 1.3 The work shall comply with the following (in order of precedence):
 - a) AS/NZS 3000: Electrical Installations (known as the Australian/New Zealand Wiring Rules);
 - b) Contract specific drawings and specified by the Principal (if any);
 - c) DPTI Technical Standards and Guidelines including standard drawings are available from the following web site: <https://www.dpti.sa.gov.au/standards>; and
 - d) any other relevant Australian Standards.
- 1.4 Where necessary, the Contractor shall liaise with SA Power Networks regarding the removal of SA Power Networks' poles and shall co-ordinate this work in conjunction with the installation and operation of the Principal's light poles.

2 Materials

- 2.1 Materials shall comply with the following:
 - a) Poles, Outreaches and Footing Units: RD-EL-S1 "Supply of Lighting Components";
 - b) Luminaries: RD-EL-S2 "Supply of Luminaries";
 - c) Conduits and Junction Pits: RD-EL-C3 "Installation of Conduits and Pits";
 - d) Footing Reinforcement: ST-SC-S6 "Steel Reinforcement";
 - e) Concrete: ST-SC-S1 "Normal Class Concrete";
 - f) Flexible Conduit: Flexible Conduit to AS/NZS 2053; and
 - g) Other Conduit: Heavy Duty Rigid PVC Conduit to AS/NZS 2053 (colour orange).
- 2.2 If the Contractor supplies frangible poles, the Contractor shall provide evidence demonstrating compliance with requirements of RD-EL-S1 "Supply of Lighting Components. Provision of the documentation shall constitute a **Hold Point**.

3 Pole Footings

Setting Out

- 3.1 The positions of the footings shall be set out from the coordinates given in the Geometric Details document, on the drawings or as referenced by chainage and offset.
- 3.2 The direction of the outreach shall be as shown on the drawings.
- 3.3 The access hatch on poles shall be positioned on the rear of the pole so that it can be easily and safely accessed. If this is not practical, it shall be positioned on the side opposite to the on-coming traffic.
- 3.4 The level and slope of the concrete surround shall match the specified finished levels and slopes for the surrounding ground.

Setting Up

- 3.5 Where steel footing units are used, the footings units shall be firmly supported to prevent movement during pouring of concrete. Where holding down bolts are used, the bolts shall be firmly held in position by a jig. The use of welding to secure the position the bolts is not permitted. All conduits shall be plugged to prevent the entry of concrete during pouring.
- 3.6 Prior to pouring concrete a **Hold Point** shall apply.
- 3.7 The level of the top of the footing mounting plate or holding down bolts shall be determined from the specified finished levels for the surrounding ground. The mounting plate shall be set to within 2 mm of the horizontal across diameters to ensure verticality of the pole.
- 3.8 Footing units or bolts shall be placed within the following tolerances:

Table RD-EL-C1 3-1 Footing Units or Bolts Tolerances

Component	Tolerance
Vertical	
Height of base (slip base poles)	+0,-10 mm
Height of threaded rod (I/A poles)	± 5 mm
Horizontal	
Distance from face of kerb	- 20 mm, + 50 mm
Chainage along kerb line	± 100 mm

Concrete

- 3.9 Concrete shall be compacted by use of a pencil vibrator. The surface of the concrete footing surround shall be a wood float finish with the edges arised with an edging tool.
- 3.10 The exposed part of the steel footing unit or exposed bolts shall be cleaned immediately after pouring of concrete is completed. All vent holes shall be left clean and have any anti-corrosive tape completely removed from the hole.
- 3.11 Where steel footing units are used, the concrete inside the footing unit shall be dished down by approximately 25 mm to the bottom of the conduit drainage holes to ensure that no water pools in the base. It shall be a smooth finish.
- 3.12 Backfill shall not cover the concrete surround.

4 Trenching, Boring and Backfill

- 4.1 Excavation and backfill of trenches shall comply with RD-EW-C4 "Trench Excavation and Backfill".
- 4.2 Under-road boring shall comply with RD-EW-C5 "Boring".
- 4.3 Reinstatement of any existing pavements to be retained shall comply with RD-PV-C6 "Reinstatement of Existing Pavements".

5 Assembly and Erection of Poles

General

- 5.1 Poles shall be assembled in accordance with the manufacturer's instructions or, if the Principal has supplied the poles, the assembly instructions included in Clause 17 of this specification.
- 5.2 If Impact Absorbing submerged base poles are used, a **Hold Point** shall apply prior to backfilling to confirm anti-corrosive treatment and grouting has been correctly applied.
- 5.3 Where the poles have base plates, wedges or pads shall be used to support the plate during the grouting process. Thin levelling nuts shall not be used to support the plate.

- 5.4 After erection, all poles shall be vertical. Poles shall be marked with the DPTI identification no. (as shown on the drawings) using a Vinyl film label with permanent acrylic adhesive (Brady B-7569 or equivalent accepted by the Principal).
- has a white background with black numbers;
 - has numbers at least 40 mm high using a bold, sans-serif font;
 - is horizontally attached to the poles at a height of 1.7 m; and
 - is orientated 45° towards the oncoming traffic so that it can be easily read from an approaching vehicle.
- 5.5 GPS coordinates (latitude and longitude) for each asset shall be provided to DPTI for inclusion in lighting database.

Slip Base Poles

- 5.6 At least 2 days prior to installation, the Contractor shall provide a copy of the current Calibration Certificate for the torque wrench. The certificate shall not be dated 12 months earlier than the Date of Acceptance of Tender. Provision of the Certification shall constitute a **Hold Point**.
- 5.7 Threads shall be cleaned to allow hand tightening of clamping bolts prior to torque being applied. The clamping bolts shall be tightened to the torque specified on the drawings using a calibrated torque wrench. The Contractor shall provide a copy of the certification that all clamping bolts have been correctly tensioned in accordance with this Clause.

6 Electrical Work

General

- 6.1 All electrical installations shall be carried out by an electrical worker who is licensed to perform any electrical works. The installations shall comply with AS 3000 and the Service Rules and Conditions of Supply of SA Power Networks.

Working in the Vicinity of Existing Overhead Cables

- 6.2 The Contractor shall:
- comply with the requirements of the Technical Regulator when working in the vicinity of existing overhead electricity cables;
 - ensure that at least one person trained in working near overhead cables is present to supervise the work taking place near overhead cables; and
 - obtain approval from the Technical Regulator before working within the restricted zone as outlined in the Office of the Technical Regulator documents Building Safely Near Powerlines and Working Safely Near Powerline, available from:
 - https://www.sa.gov.au/_data/assets/pdf_file/0003/18606/150513-Building-safely-near-powerlines-web.pdf; and
 - https://www.sa.gov.au/_data/assets/pdf_file/0003/6969/160708-Working-safely-near-overhead-powerlines.pdf.
- 6.3 Provision of the approval and evidence of training shall constitute a **Hold Point**.

Inspection

- 6.4 The Contractor shall:
- arrange for Certificates of Compliance for all electrical work;
 - provide copies of the certificates to the Principal; and
 - pay for any applicable fees for the connections.

7 Supply Points

General

- 7.1 If the Principal has made arrangements for supply point locations, the locations will be shown on the drawings. The Contractor shall confirm the position of the supply points on-site and with SAPN before installing conduit runs to these points.
- 7.2 If the Contractor is to arrange service points, the Contractor shall:
- complete and submit a SA Power Networks REX application;
 - provide a copy of the form to the Principal and the DPTI Electrical Asset Management Unit;
 - provide Certificates of Compliance to the Principal in accordance with the Electricity Act; and
 - apply for an electricity meter where required.

Temporary Supply and Service Points

- 7.3 For details of any temporary overhead supply points and / or service points refer to the Principal.

8 Service Points

General

- 8.1 SAPN underground or Stobie pole supply shall be connected in accordance with SA Power Networks service supply rules and regulations.

Layout

- 8.2 The layout of switchboards and general circuit arrangement of service points shall be substantially as shown on the drawings.

Location

- 8.3 Services fuses shall not be located in DPTI switchboards.
- 8.4 Isolation pit and fuse shall be installed in accordance with DPTI standard drawings. Three phase installation shall have all phases identified on both sides of the isolation fuse with appropriate coloured heat shrink.

9 Wiring

Combination / Combo Mast Arm poles

- 9.1 Unless specified otherwise, combination / combo mast arm poles shall be fed from the traffic signal controller.

Four Way Lighting Poles

- 9.2 Four way lighting poles shall have two circuits fed from the same phase in accordance with the drawing.

Conductors

- 9.3 Notwithstanding AS 3000, all neutrals shall have black primary insulation.
- 9.4 All active and neutral conductors shall be double insulated and comply with AS3000.

Circuit breakers

- 9.5 All circuit breakers shall be as specified in the Contract specific drawings or standard drawings.

Jointing

- 9.6 All joints below ground shall be waterproofed using DPTI approved epoxy jointing kits. "Tee-offs" shall be of equivalent size to a "Scotchcast" 90-B1 or larger.

Cable Lengths

- 9.7 Spare cable shall be installed in each junction pit equal to the length plus the width of the junction pit. Spare cable shall be installed neatly in a loop and suitably cable tied.

Earthing

- 9.8 All earthing electrodes shall be 13 mm diameter copper sheathed steel stakes. Earth electrodes shall be provided in accordance with SA Power Networks Supply and Installation rules and shall be identified and protected in accordance with AS 3000.

10 Luminaires

General

- 10.1 Luminaires shall be the type specified on the drawings and in accordance with DPTI Approved Products list.

Mounting

- 10.2 Unless otherwise specified, luminaires shall be mounted horizontally with zero degree upcast.

Conductors

- 10.3 All single insulated conductors in the luminaires shall have a heat rating appropriate for the expected temperatures in their location in the housing.

11 Lamps

- 11.1 Unless specified otherwise, luminaires shall be LED of the wattage and type specified on the drawings.

12 Other Lighting

- 12.1 Any other lighting shall be as specified by the Principal or on the drawings.

13 Acceptance

- 13.1 The Contractor shall demonstrate that all lamps are operational as designed, prior to acceptance. All pits and infrastructure shall be free of vermin and debris at the time of asset handover.

14 Removal of Existing Poles and Footings

- 14.1 Where specified, the Contractor shall remove DPTI lighting poles and footings shown on the drawings. The Contractor shall provide 2 weeks' notice prior to removal. Unless specified otherwise, backfill of holes resulting from removal of existing footings shall be in accordance with Clause 4 "Trenching, Boring and Backfill".

- 14.2 Unless specified otherwise by the Principal, ownership of the poles, footings and luminaries is vested in the Contractor, who shall remove them from the site.

15 Hold Points

- 15.1 The following is a summary of Hold Points referenced in this Part:

Document Ref.	Hold Point	Response Time
2.2	Provision of the evidence of compliance with RD-EL-S1	5 working days
3.6	Prior to pouring concrete footing	3 working days
5.2	Submerged base impact absorbing poles – prior to back-filling	3 working days
5.6	Calibration certificate for the torque wrench.	5 working days
6.3	Provision of the approval and evidence of training prior to working near overhead poles	3 working days

16 Verification Requirements and Records

- 16.1 The following is a summary of records to be supplied by the Contractor to demonstrate compliance with this Part:

Table RD-EL-C1 16-1 Verification Requirements

Document Ref.	Record
5.7	Holding Down Bolt Tension Verification Certificate
6.4	Certificates of Compliance of all Electrical Work
7.1	SA Power Networks Connection Test and Certificates of Compliance
PC-S12 "Site Surveys"	Position Verification Certificate

17 Appendix 1: Street Lighting Pole Assembly Instructions

- 17.1 The outreach is attached to the column by means of a forced tapered fit. Carrying out the following procedure will achieve an effective joint.
 - 17.2 Place column and outreach on timber bearers.
 - 17.3 Check that joint area of both sections is clean and undamaged.
 - 17.4 All columns have top OD of 100 mm and nominal lap joint length of 300 mm. Mark the minimum overlap length slightly under at approximately 250 mm.
 - 17.5 Line up the top and bottom section so that the base plate, the door and the outreach arm are in the correct relationship.
 - 17.6 To achieve the specified overlap a pulling force of up to 1.5 tonne shall be applied. During assembly, the joint area may be vibrated by tapping with a mallet, or length of wood.
 - 17.7 The force can be applied in a variety of ways, depending on the equipment available. The following methods have been found satisfactory:
 - a) With columns having mounting height of 7.5 m, or greater, a "Tirfor" Model T7 winch can be placed in the door opening and the wire rope secured at the top and bottom openings of the outreach and column.
 - b) A winch can be supported against the column base and the rope passed up through the column, secured at the tip of the outreach.
 - c) A hydraulic puller / press with the appropriate pole clamps can also be used.
 - 17.8 Ensure that the correct rotational orientation is maintained as the sections are forced together.
 - 17.9 After assembly, the joint shall be snug and the top section shall cover the minimum overlap mark.
 - 17.10 Any damage to the poles (e.g. to galvanising) shall be repaired in accordance with RD-EL-S1 "Supply of Lighting Components".
-